

# VOC Content Test Certificate

Wednesday 23<sup>th</sup> October 2019

Supplier: Flowcrete Australia Pty Ltd (Unit 2, 41 Deakin Street, Brendale, QLD, 4500).

Sample Description: Flowcrete Deckshield ED Membrane

Date Tested: October 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D2369-10: 2015 Standard Test Method for Volatile Content of Coatings: Table 1 – Method E with Induction time of 24 hours sat room temperature before putting in oven.

Test Data:

|  |  |
|--|--|
| <b>Specification</b><br><br><b>Green Building Council of Australia</b><br><b>Green Star Design &amp; As Built V1.2-13.1.1B</b><br><b>Green Star Interiors V1.2-12.1.1B</b>                     | <b>Flowcrete Deckshield</b><br><b>ED Membrane</b>                  |
| <b>One and two pack performance coatings for floors:</b><br><br><b>140 grams per Litre</b>   | <b>&lt;1 grams per Litre as VOC content</b><br><b>per material</b> |
| <p><i>We hereby certify that Flowcrete Deckshield ED Membrane is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p> |  |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Tuan Duong  
BE (Chem. Eng.)  
Consultant



Luke Morley  
BSc (Tech)  
Consultant

V1909057